

State of California
Department of Public Health
Water Treatment Device
Certificate Number

08 - 1927

Date Issued: June 12, 2008

Trademark/Model Designation

Always Fresh H₂O SF-1000

Replacement Elements

RC-SF-1000

Manufacturer: Waterline Technology

The water treatment device(s) listed on this certificate have met the testing requirements pursuant to Section 116830 of the Health and Safety Code for the following health related contaminants:

Microbiological Contaminants and Turbidity

Cysts

Turbidity

Organic Contaminants

None

Inorganic/Radiological Contaminants

Lead

Rated Service Capacity: 1000 gal

Rated Service Flow: 0.75 gpm

Conditions of Certification:

Do not use where water is microbiologically unsafe or with water of unknown quality, except that systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.